

Sample Hourly Demand Data

(The yellow highlight represents the hour beginning at 3:00 p.m. and ending at 5:59 p.m.)

Date	Day	1am	2am	3am	4am	5am	6am	7am	8am	9am	10am	11am	Noon	1pm	2pm	3pm	4pm	5pm	6pm	7pm	8pm	9pm	10pm	11pm	12am	Peak	
7/1/2015		55.5	2.18	0.80	2.24	0.74	0.86	2.24	1.09	1.15	1.20	1.26	0.86	1.38	2.47	2.82	4.20	5.29	3.34	3.05	4.60	2.53	2.07	3.91	3.45	1.84	5.29
7/2/2015		36.2	1.44	1.15	0.86	1.67	0.86	0.74	1.55	1.72	2.53	1.61	0.97	2.01	1.84	0.86	2.01	1.03	1.95	1.49	2.41	0.97	2.53	1.32	1.67	1.03	1.95
7/3/2015		48.5	0.92	0.86	0.92	0.86	0.86	1.03	1.38	1.15	1.61	2.36	3.34	2.82	1.72	1.72	3.45	2.01	3.16	2.99	2.82	1.61	1.67	2.93	3.34	2.93	0.00
7/4/2015		60.8	0.92	1.72	0.86	0.86	0.80	0.97	1.55	1.09	3.45	2.93	1.09	3.62	3.91	5.99	5.35	5.01	3.74	3.80	2.99	2.47	2.41	1.90	2.18	1.15	0.00
7/5/2015		62.6	1.84	0.86	2.24	0.86	0.92	0.86	0.92	1.61	1.55	2.76	3.16	3.28	2.88	4.32	5.24	4.66	3.97	2.82	3.74	3.34	2.64	2.93	3.68	1.55	0.00
7/6/2015		59.1	1.15	2.47	1.09	2.36	1.15	1.38	2.01	1.44	3.62	4.60	3.97	3.05	2.70	3.05	3.45	3.39	2.70	3.57	2.36	2.70	1.67	1.95	2.18	1.09	3.57
7/7/2015		41.1	0.92	1.03	1.03	0.86	1.09	1.38	1.61	1.95	1.20	2.01	1.95	1.44	1.32	1.61	1.84	2.18	1.32	2.24	2.47	2.36	1.67	3.05	3.68	0.86	2.24
7/8/2015		30.0	0.97	1.44	0.92	0.97	0.86	1.84	1.20	1.49	0.74	1.84	1.49	1.90	1.26	1.72	1.78	1.61	1.78	1.26	1.72	3.16	0.00	0.00	0.00	0.00	1.78
7/9/2015		13.0	0.00	0.00	0.00	0.00	1.90	1.49	1.67	1.32	1.90	1.95	1.26	1.49	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
7/10/2015		46.9	0.00	0.00	0.00	0.00	1.09	1.15	1.67	1.44	1.49	2.30	1.26	1.55	1.55	5.76	5.76	1.67	1.44	1.95	3.28	3.74	3.28	2.70	1.67	2.13	1.95
7/11/2015		63.4	1.15	2.30	1.09	1.15	1.15	1.32	1.90	2.07	1.78	3.62	6.16	3.68	3.05	4.32	3.16	2.64	2.70	3.28	2.82	1.55	2.82	2.53	4.03	3.16	0.00
7/12/2015		61.3	1.15	1.15	1.44	2.13	1.15	1.55	1.44	1.84	2.13	2.59	2.82	1.84	2.13	3.05	3.28	3.05	5.01	3.68	3.22	3.39	3.39	4.49	2.76	2.59	0.00
7/13/2015		69.1	1.61	2.47	1.09	1.15	1.09	2.99	1.38	1.84	1.90	3.22	2.41	2.82	2.18	4.95	3.62	4.14	5.24	4.89	4.60	4.26	3.74	3.39	2.93	1.15	5.24
7/14/2015		54.0	2.53	2.47	1.49	1.09	2.47	1.20	2.30	1.95	1.55	1.61	3.05	3.80	2.53	3.39	3.11	2.47	3.62	5.93	3.80	3.68	0.00	0.00	0.00	0.00	5.93
7/15/2015		67.6	0.00	0.00	0.00	0.00	3.16	1.26	2.07	1.67	3.91	1.84	2.13	2.93	3.57	2.99	4.08	4.14	3.28	4.20	6.73	7.02	3.34	3.80	2.88	2.59	4.20
7/16/2015		68.8	2.53	1.15	2.88	1.09	2.13	1.49	1.95	2.07	3.39	1.78	2.01	2.70	2.36	3.57	3.97	3.45	2.82	4.89	6.10	4.72	2.47	4.32	3.39	1.61	4.89
7/17/2015		77.0	2.53	1.95	1.72	1.09	2.47	1.61	1.15	1.90	3.34	5.06	5.01	5.81	6.10	3.80	3.97	4.49	3.80	3.39	3.39	2.70	3.28	3.05	2.76	2.64	4.49
7/18/2015		69.9	2.64	1.09	2.24	1.15	1.15	2.93	1.49	2.76	1.26	2.64	2.88	3.57	3.16	3.39	3.22	3.68	3.80	3.97	4.66	3.51	4.14	2.53	4.72	3.28	0.00
7/19/2015		82.1	2.30	2.01	2.59	1.15	1.78	2.36	1.49	2.76	1.84	4.37	4.83	3.45	4.32	3.97	2.99	4.32	4.26	4.55	4.89	6.56	5.81	3.68	2.93	2.88	0.00
7/20/2015		76.3	1.09	2.59	1.95	1.49	2.07	2.18	2.30	2.01	5.35	5.93	3.05	2.64	3.74	3.16	1.90	3.39	3.85	4.14	5.70	4.37	2.93	2.59	5.52	2.36	4.14
7/21/2015		47.1	2.01	2.18	1.15	2.13	1.09	2.07	3.22	1.38	1.67	1.38	1.84	2.07	1.61	1.44	2.88	1.38	1.49	1.84	1.55	1.90	3.39	3.05	1.95	2.41	1.84
7/22/2015		54.1	1.20	1.15	1.20	1.20	1.84	2.13	1.26	1.61	1.61	1.72	2.36	3.45	2.01	3.34	2.59	2.88	3.51	3.51	3.91	3.22	2.47	2.53	2.18	3.51	
7/23/2015		54.0	2.24	0.92	0.97	1.95	0.97	1.09	1.84	2.76	2.24	2.70	1.38	2.41	1.78	2.88	3.05	2.70	4.37	3.51	2.64	2.88	2.41	1.61	2.47	2.18	3.51
7/24/2015		77.9	1.09	1.72	1.09	1.09	1.90	1.90	1.15	2.82	6.04	5.29	2.76	3.62	3.97	4.72	5.35	3.51	4.95	3.97	3.97	3.97	5.64	3.05	2.41	1.95	3.97
7/25/2015		59.2	2.30	0.97	2.24	0.97	0.92	1.78	2.18	1.78	1.20	1.38	1.26	3.16	3.28	3.51	2.59	4.03	3.05	3.97	4.08	3.11	3.91	2.76	2.30	2.47	0.00
7/26/2015		68.7	1.20	2.24	1.15	2.24	1.26	1.61	1.15	1.67	2.24	2.01	5.01	8.58	3.28	4.14	3.68	3.85	3.28	3.16	2.59	2.76	4.55	2.82	2.64	1.55	0.00
7/27/2015		57.1	2.07	0.97	1.95	0.97	0.92	1.84	1.61	1.90	2.93	1.61	2.07	2.47	2.47	2.64	3.16	5.06	1.49	3.11	4.78	3.16	2.47	2.36	2.93	2.18	5.06
7/28/2015		73.5	2.36	0.97	1.67	1.55	1.49	1.26	2.64	1.95	2.47	1.84	2.82	3.34	6.33	6.62	3.11	3.57	3.51	4.66	4.08	4.08	2.76	3.74	4.14	2.53	4.66
7/29/2015		46.3	0.97	2.41	0.97	1.49	1.95	1.20	1.90	1.44	2.13	1.72	1.61	1.55	2.70	2.59	2.36	2.36	2.07	1.09	1.61	3.16	3.16	2.82	2.07	0.97	2.36
7/30/2015		48.3	1.61	0.92	0.92	1.26	0.92	1.32	2.24	1.32	3.45	3.11	2.24	1.78	1.49	1.72	3.05	2.41	1.61	2.53	3.62	3.05	1.78	2.24	2.13	1.55	2.53
7/31/2015		67.4	0.86	0.92	1.44	0.92	0.86	0.97	1.61	1.26	2.59	3.62	2.24	5.93	4.03	4.43	6.85	3.39	3.68	3.05	4.20	3.51	2.88	3.91	2.24	2.01	3.68

(Note that occasionally the above report may show "0" usage for a given hour, this does not necessarily mean there was no usage, but rather the system may not have communicated with the meter to receive that hourly read.)

Peak Demand 5.93

Yellow Highlight = Time of Use period used to determine billing demand

Green Highlight = Weekends and Holidays. These days are not used to determine your Time of Use demand.

Red Highlight = Time of Use Demand. This number represents the highest hourly demand during the Time of Use period for this month.

Total Bill:	Customer Charge	\$27.00
	Energy Charge (.07472 x 1291 kWh)	\$96.46
	Time of Use Demand (\$5.10 x 5.93 kW)	\$30.24
	Total	\$153.70